

MAIN LINE	DIMENSION "L"	
	TYPE "B"	TYPE "B" MOD.
20"	<i>33</i> "	28"
24"	36"	31"
30"	39"	34"
36"	43"	38"
42"	46"	41"
48"	49"	44"

NOTES:

- 1. FIRE HYDRANT SHALL HAVE A MAXIMUM BURY OF 7'-0". MODIFICATION OF THE HYDRANT LEAD TO MEET THIS REQUIREMENT SHALL BE IN THAT SECTION FROM THE VALVE TO THE HYDRANT AS PER STANDARD DETAIL L-7601.
- 2. FIRE HYDRANTS SHALL BE SET A MINIMUM OF 6' FROM ALL DRIVEWAY OPENINGS.
- 3. TEE USED TO CONNECT HYDRANT LEAD TO WATER MAIN IS INCLUDED IN COST OF ITEM 809, FIRE HYDRANT.

CITY OF COLUMB DEPARTMENT OF PUBLIC DIVISION OF WAT	UTILITIES		
APPROVED: RCWesterfield 1-26-18			
ADMINISTRATOR/	DATE		

STANDARD DETAIL

TYPICAL HYDRANT SETTING
TYPE "B" AND "B" MODIFIED
FOR CONCRETE AND STEEL PIPE



09 B Dwg Revision Date: 1/19/18